

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1157:104 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Digital Monitoring Products, *2500 N. Partnership Blvd., Springfield, MO
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

DESIGN: Model XR5FC and XR5SL fire alarm control units. Automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Model XR5SL does not employ a bell output circuit or 4-wire detector power, it is used for slave applications deriving its power from the host (master) control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

XR5FC, XR5SL
670, 690, 692F
865, 866
320
377

Control Panels
Keypad
Bell Module
Power Transformer
Trouble Indicator Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

The control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instructions Manual for details.

NOTE: For Alarm Verification Feature, the maximum Retard/Reset/Restart (including smoke detector reset time) shall not exceed 30 seconds.

*Rev. 03-04-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**